



**CERT**

# DIN-DVGW type examination certificate

## DIN-DVGW-Baumusterprüfzertifikat

**NG-5146CR0025**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	METSAN ENDÜSTRIYEL YAPISTIRICILAR TICARET A.S Tersane Cad. Nafe Sok., TR-34420 Karaköy - Istanbul
<b>Distributor</b> <i>Vertreiber</i>	METSAN ENDÜSTRIYEL YAPISTIRICILAR TICARET A.S Tersane Cad. Nafe Sok., TR-34420 Karaköy - Istanbul
<b>Product Category</b> <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
<b>Product Description</b> <i>Produktbezeichnung</i>	Anaerobic sealing material for metallic threaded joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2008
<b>Model</b> <i>Modell</i>	EMS Force® 5542
<b>Test Reports</b> <i>Prüfberichte</i>	type testing: 15/346/5146/2 from 12.02.2016 (EBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

**Date of Expiry / File No.** 12.02.2021 / 17-0202-GNU  
**Ablaufdatum / Aktenzeichen**

12.04.2017 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-05

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com



Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
EMS Force® 5542	class: H	for diameters > DN 10 up to DN 50

**Hints of Utilization / Remarks****Verwendungshinweise / Bemerkungen**

approved for use in coarse metallic threads

not allowed in the gas installation according to DVGW-TRGI 2008

